

PAMLICO COUNTY HEALTH DEPARTMENT

P.O. BOX 306

BAYBORO, N.C. 28515


IMPROVEMENT PERMIT

(valid 5 years)

Owner: NC Land Partners, LL
 Owner Address: 150 E. Arlington Blvd. Suite E
 Owner Address(2): Greenville, NC 27858
 Owner Phone #: (252) 355-9288
 Property Address: Carraway Cove S/D
 Property Address(2): 68 Caraway Court
 PIN: E09-19-L/E09-17
 Record: LOT # 23
 Establishment Type: Home
 Type of Well: Public Well/county
 Design Flow (GPD): 360

Initial Site
 Wastewater System: Chambered System
 Long Term Acceptance Rate(GPD/SQFT): 0.3
 Trench Width: 3 FT
 Trench Spacing (OC): 9 FT
 Trench Bottom From NGL: -12 IN
 Septic Tank Volume: 1000 GAL

Repair Site
 Wastewater System: Chambered System
 Long Term Acceptance Rate(GPD/SQFT): 0.3
 Trench Width: 3 FT
 Trench Spacing (OC): 9 FT
 Trench Bottom From NGL: -12 IN
 Septic Tank Volume: 1000 GAL



AN AUTHORIZATION TO CONSTRUCT MUST BE OBTAINED AND ALL FEES PAID PRIOR TO WASTEWATER SYSTEM INSTALLATION.

THE PAMLICO CO. HEALTH DEPARTMENT RESERVES THE RIGHT TO REVOKE THIS PERMIT IF THE SITE IS ALTERED, INTENDED USE CHANGED, OR ANY INFORMATION IS FALSIFIED.

ANY CHANGES TO THIS PERMIT WILL REQUIRE A REDESIGN PERMIT AND SUBSEQUENT FEE.

Authorized Agent:

Bryan C. Harris BS
 #1524

Date 9/18/2007